

### SV Sistemi di Sicurezza Srl

Headquarters: Via Matteotti, 55/57 24050 Grassobbio, Bergamo (Italy) Tel. +39.035.65.70.55 Fax. +39.035.66.19.64 www.svsistemidisicurezza.com email: info@svsistemidisicurezza.com

### **UE DECLARATION OF CONFORMITY**

According to the Directive of the European Parliament and of the Council of 26 February 2014

## n° 002DOC2020\_EN

1 - Product model:

EXFIRE360 - Control unit

2 – Name and address of the manufacturer:

SV Sistemi di Sicurezza Srl Via Matteotti, 55/57 24050 – Grassobbio, Bergamo ITALY

- 3 This declaration of conformity is issued under the sole responsibility of the manufacturer.
- 4 Object of the declaration:

## EXFIRE360 control unit provided with EX2GSI analogue modules

5 – The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

EN 60079-0:2009; EN 60079-29-1:2007

6 - References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 60079-0:2009; EN 60079-29-1:2007

7 – The notified body that has performed the EU-type examination:

# IMQ ISTITUTO ITALIANO DEL MARCHIO DI QUALITÀ S.p.A. - 0051

and issued the certificate no.

### **IMQ 13 ATEX 007 X**

The same notified body has assessed the conformity to type based on product quality assurance and issued the certificate no.

# **IMQ 13 ATEX 013 Q**

8 – Additional information:

Control unit EXFIRE360 is suitable for use at ambient temperatures between -5°C and +40°C. Devices installed in classified areas and connected to EXFIRE360 shall be protected with one of the types of protection listed in EN 60079-0, corresponding to their own category.

Signed for and on behalf of:

Edro Massimo Turani

Product specialist (ATEX products)

Grassobbio, Bergamo, 06th July 2020