

CERTIFICATE OF CONSTANCY OF PERFORMANCE 0051-CPR-0370

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation, or CPR), this Certificate applies to the construction product

ELECTRICAL AUTOMATIC CONTROL AND DELAY DEVICE

Trademark: SV SISTEMI DI SICUREZZA

Model: EX6EV-C,
installed on Control and Indicating Equipment model EXFIRE360

Other information: see ANNEX

Produced by:

SV SISTEMI DI SICUREZZA S.r.I.

Via Matteotti 55/57 24050 Bergamo Grassobbio (BG), Italy

In the manufacturing plant(s):

PI.M0009C

This Certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 12094-1:2003

under system 1 are applied and that the product fulfills all the prescribed requirements set out above.

This certificate cancels and replaces the certificate having the same number and issued on 2020-02-04 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

ING. V. BAGGIO
CPR TECHNICAL DIRECTOR

Milan, 2021-05-10

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011.

IMQ S.p.A. Identification Number is: 0051.



ANNEX

0051-CPR-0370

List of optional functions with requirements (EN 12094-1)

4 1 7			1.		
11 I /		\cap t	extingu	lichina	gianal
T. I /	DOIG	\circ	CAIIIIQU	אַו ווו וכוע	JIGI IGI

- 4.18 Signal representing the flow of extinguishing agent
- 4.19 Monitoring of the status of components
- 4.20 Emergency hold device
- 4.22 Initiation of secondary flooding
- 4.23 Manual only mode
- 4.24 Triggering signals to equipment within the system (by means of the board type EX6EV or EX6SO)
- 4.25 Extinguishing signals to spare cylinders
- 4.26 Triggering of equipment outside the system
- 4.27 Emergency abort device
- 4.29 Release of the extinguishing media for selected flooding zones
- 4.30 Activation of alarm devices with different signals